



क्षेत्रीय कार्यालय, सिलीगुड़ी आश्रमपाड़ा, - 734001
Regional Office, Siliguri Ashrampara – 734001

INVITATION OF BIDS / OFFERS FOR PREMISES ON LEASE

Central Bank of India requires premises measuring 92.90 to 139.35 sq.m (1000-1500 sq.ft.) carpet area in ready possession / ready for possession within 3 months at Raiganj area preferably on the ground floor with adequate parking space for their Raiganj Branch / Office and an area of atleast 1500 sq.ft extra for Currency Chest having clear height of 3000 mm.

The specifications required for Currency chest as per RBI guidelines are as follows:

Wall thickness	450mm minimum
Floor and Roof thickness	450 mm minimum
Concrete Mix	M50 minimum
Bar dia	18 mm
steel grid in walls floor and roof	mesh made by placing and tying rebars at 200 mm*200 mm cc both ways once such mesh placed staggered on both the faces of each wall floor and roof in such a manner so as to make less than 100 mm *100 mm cc through openings
Twisted tang bars laid with staggered joints and 25mm overlap minimum	2 Rows in walls 2 layers in Floor 2 Layers in Roof
Surveillance Passage/Patrol Corridor	1150 mm Minimum for front and Back 75 mm for sides
Heating ventilation and Air Conditioning arrangements	Shall be provided through plenum chamber attachment to manhole/ emergency door
Security ventilator	Height from Floor level 2100 mm minimum opening size 450 mm * 450 mm max

The area required for Currency Chest should be confirmed that there is no river or sub soil springs in the vicinity of the proposed site of construction of Currency chest strong room.

No brokers or intermediaries please. Priority will be accorded to Government / Semi Govt. bodies or public sector undertakings. Kindly download the formats / terms and conditions from the website <http://www.centralbankofindia.co.in> or collect the same from Central Bank of India Raiganj branch / Regional Office at Siliguri during office hours. The last date for submission of offers is **25.11.2023 upto 4:30 p.m.**

Chief Manager

फोन/Phone : 0353-2641391/2642417/2642485 फैक्स/FAX : 0353-2643908